

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50698653 0001

Berichtsnummer Report No.:

CN258QRA 002

Genehmigungsinhaber License Holder:

PRODUTOS ELETRONICOS METALTEX

LTDA.

R. JOSÉ RAFAELLI 221

SÃO PAULO - SP

04763-280

Brasil

Fertigungsstätte Manufacturing Site:

040-0002186910

Prüfzeichen Test Mark:


Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111308262

Geprüft nach Tested according to:

EN IEC 60947-5-1:2025

Geräteidentifikation
Product Identification
Produkt:

Mains Switch

Product:

(Control Switch)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2025-10-31

Valid from:
Zertifizierungsstelle:
Certification body:
Ausstellungsdatum:

2025-10-31

Date of issue:

Ye Ding



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com
TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50698653 0001

Berichtsnummer *Report No.:*

CN258QRA 002

Produkt *Product:* Mains Switch
(Control Switch)

Modell *Type:* **Bezeichnung** *Designation:*

Type Designation : NP20

Utilization Category : AC-15; DC-13

Rated Operational Voltage : 240V

Rated Operational Current : 3A

Rated Frequency : 50/60Hz for AC

Conventional Free Air

Thermal Current : 10A

Rated Insulation Voltage : 500V

Rated Impulse Withstand

Voltage : 2,5kV

Pollution Degree : 3

Conditional Short-circuit

Current : 1kA

IP code : IP40, after installation

Rated voltage of indicator
light : AC/DC 220/24V

Rated current of indicator
light : ≤20mA

Mounting hole size : D22

